



Number 103086/01 **Replaces** -
Issue date 18-10-2019 **Scope** NEN 7120+C2:2012/C5:2014
Report number 190800671

Declaration regarding the efficiency of a shower heat recovery unit

This declaration is based on a single examination by Kiwa on product:

Passive Shower Ecotray One

Supplier **Cerian Shower S.L. Spain**

The product was tested according the procedure stated in annex B of the NEN 7120+C2:2012/C5:2014.

Class	Flow (l/min)	Volume (l)	Efficiency (%)	Flow resistance (ΔP) (bar)
2	5.8	46	40.7	0.168
3	9.2	73	37.0	0.410
4, 5, 6	12.5	100	34.4	0.735
-	11	88	35.3	0.641

This declaration does not pass a judgment on other products supplied by the manufacturer.

Allard Slomp
Productmanager

Kiwa Nederland B.V.



Kiwa Nederland B.V.
Wilmersdorf 50
Postbus 137
7300 AC Apeldoorn
Tel. +31 88 998 33 55
Fax +31 88 998 36 85
E-mail eup@kiwa.nl
www.kiwa-eup.nl

Cerian Shower S.L. Spain
Ronda Alzira No 6
46680 Algemesi
Spain
Tel. +34 605 95 12 57
E-mail info@passiveshower.com
www.passiveshower.com